

**DANGER**

Causes severe skin burns and eye damage. Causes serious eye damage.

Do not breathe mist, spray. Wash thoroughly after handling. Wear eye protection, protective clothing, protective gloves.

**IF SWALLOWED:** Rinse mouth. Do NOT induce vomiting.

**IF ON SKIN (OR HAIR):** Take off immediately all contaminated clothing. Rinse skin with water/shower.

**IF INHALED:** Remove person to fresh air and keep comfortable for breathing.

**IF IN EYES:** Rinse cautiously with water for several minutes. Remove contact lenses, if present and easy to do. Continue rinsing. Immediately call a doctor, a POISON CENTER. Specific treatment (see First aid measures on this label).

Wash contaminated clothing before reuse.

Store locked up.

**WARNING:** This product can expose you to Acrylamide, which is known to the State of California to cause cancer and birth defects or other reproductive harm. For more information go to [www.P65Warnings.ca.gov](http://www.P65Warnings.ca.gov).

**NFPA® RATINGS**

Health: 2; Flammability: 0; Reactivity: 0

**CONTAINS/CAS NUMBER:**

Water/7732-18-5; Acrylamide-Acrylic Acid Copolymer/Withheld; Sodium Hydroxide/1310-73-2; Amino-Methylene Phosphonic Acid/Withheld; Sodium Molybdate/10102-40-6

*For industrial and commercial use only.*

*For additional information, see Safety Data Sheet.*

# TOTAL SOLUTIONS®

WATER TREATMENT

## TOWER TREAT "H"

Scale and Corrosion Inhibitor  
for Cooling Towers Using  
Hard Water

**KEEP OUT OF REACH OF CHILDREN**

**NET CONTENTS:** One Gallon (128 fl. oz.)

Manufactured By: Total Solutions®  
PO Box 240014 • Milwaukee, WI 53224 • 1-800-743-6417

**DESCRIPTION**

This scale and corrosion inhibitor is specifically formulated for open recirculating cooling water systems in areas of high hardness, high alkalinity scaling waters. It contains a strong calcium carbonate crystal modifier, which prevents calcium carbonate deposition, along with a yellow metal protectant. Contains a polymer designed to inhibit scale and deposition in a wide variety of aqueous systems.

**DIRECTIONS**

Dosages will depend on the characteristics of the make-up water, the permissible cycles of concentration and cooling towers rated tonnage versus its operational tonnage.

This product should be fed at a rate of 200 to 400 ppm (25 to 50 ounces per 1000 gallons of cooling water capacity).

It should be fed to maintain a residual molybdate test level of between 1.2 and 2.4 ppm molybdate.

It is recommended that this product should be fed on a continuous basis using a suitable treatment pump and control unit. It may be fed directly from the drum or diluted to a convenient concentration with water. It should be fed to a point in the system where it will be thoroughly mixed and evenly distributed. It should be used in conjunction with an alternating algacide and biocide treatment program.

**DISPOSAL**

Dispose of contents/container to comply with local/regional/national/ international regulations.



Please Recycle.

1933.110821