



DANGER

Harmful if swallowed. Causes severe skin burns and eye damage. Causes serious eye damage.

Do not breathe mist, spray. Wash thoroughly after handling. Do not eat, drink or smoke when using this product. Wear eye protection, protective clothing, protective gloves.

IF SWALLOWED: Rinse mouth. Do NOT induce vomiting. Call a doctor, a POISON CENTER if you feel unwell.

IF ON SKIN (OR HAIR):): Take off immediately all contaminated clothing. Rinse skin with water/shower.

IF INHALED: Remove person to fresh air and keep comfortable for breathing.

IF IN EYES: Rinse cautiously with water for several minutes. Remove contact lenses, if present and easy to do. Continue rinsing. Immediately call a POISON CENTER, a doctor.

Specific treatment (see First aid measures on this label).

Rinse mouth.

Wash contaminated clothing before reuse.

Store locked up.

WARNING: This product can expose you to Formaldehyde, which is known to the State of California to cause cancer. For more information go to www.P65Warnings.ca.gov

NFPA® RATINGS
Health: 2; Flammability: 0; Reactivity: 0

CONTAINS/CAS NUMBER: Water/7732-18-5; Potassium Hydroxide/1310-58-3; Amino-Methylene Phosphonic Acid/Withheld; Acrylic Polymers/Withheld; Phosphoric Acid/7764-38-2

For industrial and commercial use only.
For additional information, see Safety Data Sheet.

TOTAL SOLUTIONS®

WATER TREATMENT

TOWER TREAT “S”

Scale and Corrosion Inhibitor
for Cooling Towers Using
Soft Water

KEEP OUT OF REACH OF CHILDREN

NET CONTENTS: One Gallon (128 fl. oz.)

Manufactured By: Total Solutions®
PO Box 240014 • Milwaukee, WI 53224 • 1-800-743-6417

DESCRIPTION
This product is a scale and corrosion inhibitor specifically formulated for open recirculating cooling water systems in areas of low hardness, low alkalinity and highly corrosive waters. It contains a superior phosphate corrosion inhibitor and yellow metal protectant. This product also contains a polymeric dispersant to ensure sludge and scale are easily removed from the system through a regular bleed-off program.

DIRECTIONS
Dosages of this product will depend on the characteristics of the make-up water, the permissible cycles of concentration and a cooling towers' rated tonnage versus its operational tonnage. This product should be fed at a rate of 300 to 500 ppm (40 to 64 ounces per 1000 gallons of cooling water capacity). It should be fed to maintain a residual molybdate test level of between 1.2 and 3.0 ppm molybdate.

It is recommended that this product be fed on a continuous basis using a suitable treatment pump and control unit. It may be fed directly from the drum or diluted to a convenient concentration with water. It should be fed to a point in the system where it will be thoroughly mixed and evenly distributed. This product should be used in conjunction with an alternating algacide and biocide treatment program.

DISPOSAL
Dispose of contents/container to comply with local/regional/national/international regulations.



Please Recycle.

1935.111721